



Mirjoli Muslim Anjuman Mumbai's
National English Medium School & Junior College

(PRIMARY / SECONDARY SECTION)

ए.एन.एस. - १००३/८१०१/०३/म. वि. ३ / S.S.C. Index Code No. 25.01.067

Primary Udise : 27320102303 / Secondary Udise : 27320102304

At. MIRJOLI, TAL. CHIPLUN - 415605, DIST. RATNAGIRI,

Mob. 9096001855 / 9049585345

Email : administration@nationalschoolchiplun.edu.in

OW/PS/122/23-24

Declaration regarding fire NOC

As per the provisional NOC, we are making the required changes but due to the safety reasons the work couldn't not proceed with usual speed as the school is actively open with regular schedule still we are trying to make it as early as possible.

As per mentioned in the last point of Provisional NOC, it states that there would be an inspection in order to check the fire safety instruments and give the NOC, but the current NOC is valid till the new NOC is being issued.

Date: 23/12/2023

Headmistress
National English Medium School
& Jr. College, Mirjoli
Chiplun, Dist. Ratnagiri

Manager
NATIONAL ENGLISH MEDIUM SCHOOL &
JUNIOR COLLEGE
MIRJOLI, TAL. CHIPLUN, DIST. RATNAGIRI



भारतीय मानक ब्यूरो
Bureau of Indian Standards
 The National Standards Body of India

For any other communication

Mumbai Branch Office-I-5th Floor, MTNL CETTM Technology Street, Hiranandani Garden, Powai, Mumbai, Mumbai, MUMBAI CITY, MAHARASHTRA, 400076
 Address: Phone: 022-26329295, 25702721
 Fax: 02228364926
 E-Mail: muboi@bis.gov.in
 Web: www.bis.org.in, www.marakonline.in

BUREAU OF INDIAN STANDARDS

Attachment to Licence No. CML- 7331058

CML-No	Name of the Licensee with the Factory Address	Name of the Product	Inding Standard No.
7331058	PETER AUTOKITS PLTD -Plot No. 56, Survey No.75, Village-Valiv, Near Alkon Plastics, Taluka-Vasai (East), vasai, palghar : 401208	PORTABLE FIRE EXTINGLISHERS- PERFORMANCE AND CONSTRUCTION - SPECIFICATION	IS 15683 : 2018

Endorsement No. 33 Dated 13-Jun-2023

Whereas, the licence was valid upto First July Two Thousand Twenty Three.

Now, consequent upon renewal, the validity of the licence given in schedule of the Licence Dated 30-JUN-2023 has been extended from First July Two Thousand Twenty Three to Thirty June Two Thousand Twenty Four

Other terms and conditions of licence remain same.

Branch Head (Mumbai Branch Office-I)

Manak Bhavan, 9 Bahadur Shah Zafar Marg, New Delhi 110002, 9 Bahadur Shah Zafar Marg, DELHI, 110002

Contact No: +91 11 23230131, 23233375,
23239402

Fax: +91 11 23234062, 232

Email: info@bis.gov.in

1. 9kg ABC F/E - 7 NOS
1525-1532

2. 4.5kg CO2 F/E - 2 NOS
2964-2965.

SAFETY PLUS



Certificate issued against material supplied to

MS. Suremi Safety Services

vide Bill No. 1310/23-24 Date 22-12-23

Product 9kg ABC / 4.5kg CO2 F/E

Bearing No. 7-1-9 NOS





MAHARASHTRA INDUSTRIAL DEVELOPMENT CORPORATION
(Govt of Maharashtra undertaking)

No. MIDC/FSMAHAD/MFS/FPF/52/2022
Tel No. 02145-232405
Fax No. 02145-233001

Office of the Divisional Fire Officer
MIDC Fire Station, Lote Parshuram
Plot No. P-33, MIDC, Indl. Area, Lote
Parshuram, Tal- Khed Dist- Ratnagiri
Date:- 13/05/2022

To,
M/s. Mirzoli Musliman Anjuman Sanstha Mumbai,
S. No. 19A, H. No. 15 & 16, At. Mirzoli,
Tal. Chiplun, Dist. Ratnagiri

**Sub: NOC stipulating fire protection and firefighting requirements
for Proposed Construction of Educational Building of M/s.
Mirzoli Musliman Anjuman Sanstha Mumbai, on H. No. 15 & 16,
At. Mirzoli, Tal. Chiplun, Dist. Ratnagiri.
Ref. Application inward No. 21/2022, Dated 21.07.2022.**

This is a proposal for construction of Education building (School Building) having Built up Area 4648.96 Sq. M. (Ground Floor + upper three Floor). Height of the Building is 14.99 Mtrs. From ground level to Terrace of the building.

The detail of the proposed Construction is as under,

Educational Building (School Building) :

Sr. No.	Floor	Proposed Built Up Area in Sq. Mtrs	Height in Mtrs
01	Ground Floor	1338.35	14.99 Mtrs
02	First Floor	1338.35	
03	Second Floor	1338.35	
04	Third Floor	669.91	
Total Built up Area in Sq. Mtrs		4684.96	

Total Plot area is 5400.00 Sq. mts and Proposed built up area is 4648.96 Sq. mts & Height of the Building is 14.99 Mtrs. From ground level.

The site abuts on 20.00 mtrs. Wide Road on South side. The open spaces around the building are as follows:

Direction	Building line to plot boundary in Mtrs
Front	5.79
Rear	3.00
Left side	3.00
Right Side	Connected Existing Building

1



Provisions of Maharashtra Fire Prevention and Life Safety Measures Act, 2006

1. Under **Section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" (hereinafter referred to as "said Act"). The applicant (developer, owner, occupier by whatever name called) shall comply with all the Fire and Life Safety measures adhering to National Building Code of India, 2016 and as amended from time to time failing which it shall be treated as a violation of the said Act.
2. As per the provision as **under :- 10** of the said Act. No person other than the License Agency shall carry out the work of providing Fire Prevention and Life Safety Measures or performing such other related activities required to be carried out in any place or building or part thereof provided that,
 - A) If the Director, MFS is satisfied that, for any reason, to be recorded in writing, the owner or occupier is not able to carry out the fire prevention and fire safety measures in any such place or building or part thereof through a Licensed Agency, he may authorize any person or persons he thinks fit to carry out such work, and any work carried out by such authorized person or persons shall be deemed to be carried out by a Licensed Agency.
 - B) No Licensed Agency or any other person claiming to be such Licensed Agency shall give a certificate **under sub-section (3) of section 3** regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance. The names of the License Agencies approved by Directorate of Maharashtra is available on our website www.mahafireservice.gov.in
3. Though certain conditions are stipulated from the said Act and the National Building Code of India, it is obligatory on part of the applicant that is developer, builder, occupier, owner, tenant, by what so ever named called to abide with the provisions of the said Act failing which it shall be actionable under the provisions of said act.
4. The plans of the building should be approved by The Concern Competent Authority.
5. The Occupancy certificate should be obtained from The Competent Authority. **The O.C. shall be issued subject to "Final No-Objection Certificate" from this Department.**
6. Proper roads in the premises should be provided & marked on ground for easy mobility of the Fire Brigade Appliance as per the guidelines given in NBC-2016, should be kept free from obstructions all the time. The load bearing capacity of internal roads must be minimum 45Tones. The width of the road shall not be less than 6.0 Mtrs for easy maneuver of the fire engine. However, the marginal open space shall be seen in to by the concern competent authority of the building proposal department.
7. Inspection of Fire Fighting installation will be carryout by the representative of this Fire department during installation of the Fire fighting system.
8. All portable fire fighting equipments installed at various locations as per local hazard such as Co2-DCP, Foam, Fire buckets should be strictly confirming to relevant IS specification. All the fire fighting equipments shall be well maintained and should be easily accessible in case of emergency. The monitoring mechanism for all Fire Fighting equipment should be designed and implemented. **The Guidelines should be followed based on IS 15683 & 18-**



2190 - Code of Practice for selection, installation and Maintenance of Portable First-Aid Fire Extinguishers.

9. All the fire fighting equipments shall be well maintained and should be easily accessible in case of emergency.
10. Emergency Telephone numbers like "Police", "Fire Brigade", "Hospital", "Doctors", and "Responsible persons of the company" should be displayed in security cabin & production building.
11. It shall be ensured that security staff & every employee of the co. are trained in handling fire fighting equipments & fire fighting.
12. "Fire Extinguisher", "Fire Bucket" "Danger" "No Smoking" caution boards should be displayed at the places physically shown & the caution boards should be easily visible and as per the guidelines given in IS:9457, IS:12349 and IS:12407.
13. The house keeping shall be well maintained within the entire plant area.
14. Fire buckets 04Nos. filled in with fine sand and will have to be installed near transformer yard & utility areas and should be easily accessible in case of emergency.
15. The Fire Exit Drill or Evacuation Drill should be plan and instruction should be given to the staff minimum **four times** in a year and drill should be carried out **twice** in a year.
16. In future if the company / developer / institute intends to go for expansion, alteration, modification of any building an approval of fire department must be obtained before commencing proposed construction.
17. Stability certificate to all buildings shall be obtained from Architect or competent person as per the Rule 3-A of Maharashtra Factories Rules, 1963.
18. All necessary approvals required from Government / Planning / Special Planning Authority shall be obtained, as applicable.

Requirement and Provision: - The following active fire protection system will be required for the safety of the proposed building :-

Sr. No.	FIRE FIGHTING INSTALLATION	Requirements	Provision	Remarks
1	Portable Fire Extinguishers	Required	IS: 15683 & 2190	
2	Hose Reel	Required at prominent places.	In all staircases of building	On each floor in the Staircase landing for Fire Fighting. The first aid hose reel shall be connected directly to riser/down comer main and diameter of the hose reel shall not be less than 19mm confirming to IS 884:1985
3	Down Comer	Required	In all staircases of buildings	Required to provide in the Staircase and Fire Escape Staircase. Landing of Valve should be installed confirming to IS:5290.
4	Fire Pump	01 No. 900 lpm Terrace pump		Fire Fighting pumps shall be well maintained. Fire pumps shall be centrifugal pumps only. Booster pump should be



[Handwritten signature]

Sr. No.	FIRE FIGHTING INSTALLATION	Requirements	Provision	Remarks
				provided on terrace on each wings of each Building
5	Terrace Level Tank	Required 25,000 Ltrs.		Tank shall be provided on each Terrace / each Wings of building
6	Manually Operated Fire Alarm System	Required	At Various strategic location	MOEFA system also include talk-back system and PA System; it should be connected to alternate power supply.
7	Fire Brigade Connection For Static Water Tank and For Hydrant System	Required at the Main Gate		
8	Automatic Detection System Required on each floor	Required in all offices, computer labs, Library, Laboratory	Automatic Detection system should be provided. Standards and guidelines given in IS-11360-1985 specification for Smoke Detectors for use in Automatic Electrical Fire Alarm system. Detection system for Cable Trench should be provided. Heat Detectors should be provided for Canteen Area as per the standards and guidelines given IS-2175-1988 specification for Heat sensitive Fire Detectors for use in Automatic Fire Alarm System.	
9	Sign Indicators for all fire safety, safe evacuation of occupants in case of emergency signs	Required at Prominent Places.	Sign indicators should provided at prominent places as per the guidelines given in IS:9457 for Safety colour and Safety IS:12349 for Fire Protection Safety Signs IS:12407 for Graphics symbols for Fire Protection Plan.	

Note: Fix fire fighting installations such as down commer, hydrant connections, hose reels etc. shall be provided in separate shaft having opening at floor level with Glass

GUIDELINES FOR INTERNAL STAIRWAYS as per NBC 2016

- Stairways shall be constructed of non-combustible materials throughout. Hollow combustible construction shall not be permitted. Width of Staircase should be 2.0 M.
- No Gas piping shall be laid down in the stairway.
- Internal staircase shall be constructed as a self-contained unit with at least one side adjacent to an external walls and shall be completely enclosed.
- Internal staircase shall not be arranged around lift shaft unless the later is entirely enclosed by material of fire resistance rating as that for type of construction itself.
- The access to main staircase shall be gained through at least half-an-hour fire resisting automatic closing doors, placed in the enclosing walls of the staircase. They shall be swing type doors opening in the direction of the escape.



- f) No living space, store or other space, involving fire risk, shall open directly in to staircase.
- g) The external exit door of a staircase enclosure at ground level shall open directly to the open space or should be accessible without passing through any door other than a door provided to form a draught lobby.
- h) The exit signs with arrows indicating the escape routes shall be provided at a height of 1.5 m. from the floor level on the wall and shall painted with fluorescent paint. All exit signs should be flush with the wall and so designed that no mechanical damage to them can result from the removing furniture, material or any other equipment
- i) Exits shall be so located that it will not be necessary to travel more than 22.5 m. from any point to reach the nearest exit.

STAIRCASE DESIGN REQUIREMENT:

1. The minimum headroom in a passage under the landing of a staircase and under the staircases shall be 2.2 Mtrs.
2. Access to main staircase shall be through a fire / smoke check door of a minimum 2 hours fire resistance rating.
3. No living space, store or other fire risk shall open directly in to the staircases.
4. The main and external staircases shall be continuous from ground floor to the terrace level.
5. No electrical shafts, A/c ducts or gas pipe etc. shall pass through or open in the staircases. Lifts shall not open in staircases.

Guidelines for School Buildings

1. The Urban Development Department Govt. of Maharashtra had issued guidelines for Safety of Educational Buildings vide letter No. FFS-2004/419/CR-121/UD-6, Dt. 05/08/04 & Circular issued by School Education Department, Govt. of Maharashtra vide No. 2004/(155/04)/Training-4, Dt. 22/07/04 which shall be scrupulously followed.
2. Building intended for educational occupancy shall not be used for any hazardous occupancy.
3. Storage of Volatile Flammable Liquids shall be prohibited and handling of such liquids shall be restricted to Science Laboratories only.
4. Exits and other means of Escape like Corridor & Staircase shall be kept free from any kind of Obstruction & Combustible Materials such as Benches, Chairs etc. Combustible materials like Old Newspaper, Wooden Furniture's, Gunny Bags etc., shall not be kept store on the Lofts.
5. Exits should be clearly visible and the route to reach the exits shall be clearly marked sign posted to guide the students (occupants) of the floor concerned.
6. Exits shall be so arranged that at least two separate exits are available in every floor area. Exits shall be as remote from each other as practicable and so arranged that there are no pockets or dead ends.
7. During Annual Function or any programmers where temporary structure i.e. Pandal or Shamiyana is erected; proper approval from Fire Department is to be taken. All necessary guidelines issued by Fire Department shall be scrupulously followed.
8. Every room or class room with a capacity of more than 45 persons in area shall have at least two doorways for exit of not less than 900 m.m. wide



[Handwritten signature]

GUIDELINES FOR CHEMICAL LABORATORY :

- a. Guidelines should be followed from IS:4209 Code of Safety in Chemical Laboratories
- b. Portable fire fighting equipments should be installed at various locations in the Administrative Building, Office Building and Stores, such as Co2-DCP, Foam, Fire buckets should be strictly conforming to relevant IS specification. All the fire fighting equipments shall be well maintained and should be easily accessible in case of emergency.
- c. In addition to this 4 Nos. of 4.5 Kgs DCP Extinguishers should be installed within the Laboratory.

ELECTRICAL SERVICES:

1. The electric distribution cables/wiring shall be laid in separate duct. The duct shall be sealed at every alternate floor with non-combustible materials having same fire resistance as that of the duct.
2. Water mains, telephone lines, intercom lines, gas pipes or any other service lines shall not be laid in the duct of electric cables.
3. Separate circuits for water pumps, lifts, staircase & corridor lighting shall be provided directly from the main switch gear panel and these circuits shall be laid in separate conduit pipes so that fire in one circuit will not affect the others.
4. The inspection panel doors and any other opening in the shaft shall be provided with airtight fire doors having the fire resistance of not less than two hours.
5. Medium & low voltage wiring running in shaft and within fall ceiling shall run in metal conduit.
6. An independent & well-ventilated service room shall be provided on the ground floor with direct access from outside or from the corridor for the purpose of termination of electric supply. The doors provided for the service room shall have fire resistance of not less than two hours.

Electric cable shaft and electric meter room :

- i) Electric cables shall not pass through the staircase walls or shall be taken in concealed manner.
- ii) Inspection door of the shaft if provided shall have two hours of fire resistance.
- iii) Electric meter room shall be provided at the ground floor at the location marked on the plan. It shall be adequately ventilated.
- iv) Electrical shafts shall be sealed at each floor level with non combustible material such as vermiculite concrete.
- v) Electric wiring shall be having copper core having the fire resistance and low smoke hazard cables for the entire building with provision of ELCB / MCB in electrical installation of the building.

Access :-Two entrance gates each of width not less than 04.50 mtr and height clearance not less than 04.50 mtrs shall be provided.

Courtyards :-

- i) The courtyards on all sides of the building shall be paved suitably to bear the load of fire engines weighing up to 45m. tones and shall be flushed to road level.
- ii) The courtyards shall be in one plane.
- iii)

PORTABLE FIRE EXTINGUISHERS :-

- a. Two Dry Chemical Powder (A.B.C.) type fire extinguisher of 4 kgs. Capacity and CO2 Type of Extinguisher of 4.5 kg having I.S.I. certification mark and



[Handwritten signature]

two buckets filled with dry, clean sand shall be kept in Electric meter Room as well as Lift Machine room of each building.

- b. Adequate Nos. of Dry Chemical Powder (A.B.C.) type fire extinguishers each of 4 Kgs. Capacity having I.S.1 (15682 & 2190) certification mark shall be kept at parking area equally distributed at prominent places in stairs.

TERRACE DOOR:

- i) The top half portion of the doors shall be provided with louvers.
- ii) The latch- lock shall be installed from the terrace side at the height of not more than 1mtrs.
- iii) The glass front of 6 inch diameter with the breakable glass shall be provided just above the latch lock, so as to open the latch in case of an emergency by breaking the glass.

SIGNAGES :-Self glowing / fluorescent EXIT signs in green colour shall be provided showing the means of escape for the entire building.

In addition to the above, all provision under the National Building Code of India-2016 shall be strictly adhered, also if any change in activity or Proposed expansion or Subletting of Plot, NOC from this department is essential.

This is a "Provisional No-Objection Certificate". After compliance with above mentioned recommendations / conditions, inspection of the fire prevention & protection systems provided by you will be carried out by this department & after satisfactory performance of the system "Final No-Objection Certificate" will be issued.

The undersigned reserves right to amend any additional recommendations deemed fit during the final inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company.

As per Maharashtra Fire Prevention and Life Safety Measures Act, 2006, Section 25-Annexure-Part III, M/s. Mirzoli Musliman Anjuman Sanstha Mumbai has paid Fire Protection Fund Fees amounting to Rs. 40,000/- (Rs. Thirty Thousand Only) vide NEFT No. KKBKH22209757395, dated 28.06.2022.

However, Town Planning is requested to verify the total built up area and inform this Department for the purpose of levying additional Capitation fee.



(A S Parab)
Divisional Fire Officer,
MIDC, Konkan Region.

Copy submitted to:

1. The Asst Director, Town Planning, Dist – Ratnagiri..
2. Director, MFS Mumbai for information, Please.

Swami Safety Services

SUPPLIER OF SAFETY MATERIAL & FIRE EXTINGUISHER

Swami Building, Pethmap Area, Parit Lane, Chiplun, Tal - Chiplun, Dist - Ratnagiri - 415 605
Cell. 9850222169, 📞 02355-259467, Email ID - swamisafetyservices@yahoo.co.in

Ref.

Date -

REF: SSS /2023-24/419

Date : 22.12.2023

To,
M/s National English Medium School & Jr.College
Mirjoli, Chiplun

Refilled Certificate

This is to certify that the Fire Extinguisher refilled in following cylinder as per IS:2190 standards. During Refilling we are checking the Grip Nozzle, Hose Pipe & Cap.

Our Delivery challan no 371 Dt. 27.12.2023 is warranted for a period of one Year from the date of refilling for any low pressure defect. If any defects are noticed during this warrantee period, the same will be rectified / replaced by us provided the material.

Sr.No	Type of Fire Extinguisher	Extinguisher No.	Qty	Refilling Date	Next Filled Due Date
01	ABC 4 Kg	3198,3197,216	03	22.12.2023	21.12.2024
02	ABC 9 Kg	2311/12/13/14/15/16/17/18/19/2320	10	22.12.2023	21.12.2024
03	DCP 10 Kg	2483,2482,3375	03	22.12.2023	21.12.2024

For Swami Safety Services

Authorised Signatory



Swami Safety Services

SUPPLIER OF SAFETY MATERIAL & FIRE EXTINGUISHER

Swami Building, Pethmap Area, Parit Lane, Chiplun, Tal - Chiplun, Dist - Ratnagiri - 415 605
Cell. 9850222169, ☎ 02355-259467, Email ID - swamisafetyservices@yahoo.co.in

Ref.

Date -

REF: SSS /2023-24/417

Date : 27.12.2023

To,
M/s National English Medium School & Jr.College
Mirjoli, Chiplun

TEST WARRANTEE CERTIFICATE

This is to certify that the following Fire Extinguisher have been tested by us. As per relevant IS specification and supplied to M/s National English Medium School & Jr.College, Mirjoli, Chiplun, Dist – Ratnagiri vide our challan No .372 dt 27.12.2023 is warranted for a period of one year from the date of supply for any manufacturing defect.

Sr.No	Type of Extinguisher	Qty	IS No	Sr.No Extinguisher
01	ABC type Stored Pressure 9 kgs capacity Fire Extinguisher, fabricated from MS tubes, fitted with brass forged squeeze grip valve assembly incorporated with pressure gauge, initial charge of 9 kgs, ABC Powder (MAP90%) and pressurized with nitrogen gas. M.S Body as per IS:513 Forged Brass valve as per IS:6912. Bearing ISI Mark IS:15683. Operating Temperature (-)20°C to (+) 55°C Suitable for : 'A' 'B' 'C' class of Fire	04	15683	1528-1532

We also certify that the above ABC Type Fire Extinguisher are hydraulically tested 100% at 35bar and found satisfactory.

Further, we certify that the above material are made of best quality in workmanship free from all defects in material and workmanship, if any inconsistency in the performance of the material in that event we undertake free repair or replacement during the warrantee period.





PRICE SUMMARY

Client: National English Medium School-mirzoli
Site -At. Mirzole, Tal. Chiplun , Dist.Ratnagiri
Qtn Ref No: AISS/23-24/196
Date: 25.10.2023

Revision - 1

Sr. No.	System Description	Document	Supply	Installation	Total Amount
1	Pump House	Annexure-I	1,20,752.94	35,588.80	1,56,341.74
2	Hydrant System	Annexure- II	4,92,655.90	1,16,277.20	6,08,933.10
3	Fire Alarm System	Annexure-III	2,79,365.00	1,20,183.00	3,99,548.00
4	Fire Extinguishers & Signanges	Annexure-IV	60,652.00	9,369.20	70,021.20
5	Talkback PA System	Annexure-V	1,12,100.00	42,480.00	1,54,580.00
Grand Total (Inclusive of Gst)					13,89,424.04

P-73, C/O Maharashtra Agro Industries Development Corporation, Near Dmart , MIDC Mirjole , Ratnagiri , Maharashtra- 415 639
Email Id : aiss.2012@rediffmail.com

Contact No : 8975349359 ,9881078084,9404769385

**Mirjoli Muslim Anjuman Mumbai's
National English Medium School & Jr College
Fees Structure (Yearly)**

I to IV	School Fees 23-24
1 Term	935.00
II Term	935.00
T Fee	1,100.00
E-L Fee	330.00
Annual Coll	650.00
Diary & i Card	125.00
Insurance	425.00
Study M	550.00
Building	400.00
Activity	300.00
Admission Fee	200.00
Computer Fee I Term	450.00
Computer Fee II Term	450.00
June Fees	6,850.00
T Fee (July to May)	12,100.00
E-L Fee (July to May)	3,630.00
Total Yearly Fee	22,580.00

V to VII	School Fees 23-24
1 Term	935.00
II Term	935.00
T Fee	1,170.00
E-L Fee	330.00
Annual Coll	650.00
Diary & i Card	125.00
Insurance	425.00
Study M	550.00
Building	400.00
Activity	300.00
Computer Fee I Term	450.00
Computer Fee II Term	450.00
June Fees	6,720.00
T Fee (July to May)	12,870.00
E-L Fee (July to May)	3,630.00
Total Yearly Fee	23,220.00

VIII to X	School Fees 23-24
1 Term	935.00
II Term	935.00
T Fee	1,185.00
E-L Fee	345.00
Annual Coll	650.00
Diary & i Card	125.00
Insurance	425.00

Study M	550.00
Building	400.00
Activity	300.00
Admission Fee	200.00
Computer Fee I Term	450.00
Computer Fee II Term	450.00
June Fees	6,950.00
T Fee (July to May)	13,035.00
E-L Fee (July to May)	3,795.00
Total Yearly Fee	23,780.00